



# 2023 ASHRAE WINTER CONFERENCE

ATLANTA, Feb 4-8 | AHR Expo, Feb 6-8



## Seminar 62: The Risk of Decoupling Efficiency and Decarbonization Presentation #33030 / #33031

### Electrification vs. Decarbonization: When does electrification of heat *not* decrease emissions?

Dan Gentry, Applications Engineer, Trane, [dan.gentry@trane.com](mailto:dan.gentry@trane.com)

Emma Van Fossen, Energy Engineer, Trane, [emma.vanfossen@tranetechnologies.com](mailto:emma.vanfossen@tranetechnologies.com)



# Seminar Learning Objectives

## Learning Objectives:

1. Understand the risks associated with incorporating carbon free solutions on end use or primary efficiency.
2. Explain the major factors impacting emissions from electrified heating.
3. Provide examples of how in certain cases electrification of heating can actually increase heating emissions.
4. Offer general guidelines for assessing the best decarbonization strategy for heating systems

*ASHRAE is a Registered Provider with the American Institute of Architects Continuing Education Systems. Credit earned on completion of this program will be reported to ASHRAE Records for AIA members. Certificates of Completion for non-AIA members are available on request.*

*This program is registered with the AIA/ASHRAE for continuing professional education. As such, it does not include content that may be deemed or construed to be an approval or endorsement by the AIA or any material of construction or any method or manner of handling, using, distributing, or dealing in any material or product. Questions related to specific materials, methods, and services will be addressed at the conclusion of this presentation.*

# Acknowledgements

- Sarah Hilden, Applications Engineer, Trane

Bias disclosure: Employed by Trane Technologies Plc.

# Outline/Agenda

1. Background
  1. Finding emissions factors
  2. Scenario & baseline system characteristics
2. Electrification options
  1. Electric boilers
  2. Air-source heat pump
  3. Ground Water heat pump
  4. Air-source heat pump, high efficiency chiller, and heat recovery chiller
3. Conclusions
  1. Emissions comparison
  2. Key takeaways

# Background & Baseline System

# Emissions Factors

What are they?

$$\text{Annual emissions} = \text{Energy Consumed} \times \text{Emissions factor}$$


Public data source used in this example for fossil fuels:

Carbon Dioxide Emission Coefficients, U.S. Energy Information Administration (2022)

Carbon Dioxide (CO <sub>2</sub> ) Factors:	Pounds CO <sub>2</sub>	Kilograms CO <sub>2</sub>	Pounds CO <sub>2</sub>	Kilograms CO <sub>2</sub>
	Per Unit of Volume or Mass	Per Unit of Volume or Mass	Per Million Btu	Per Million Btu
<b>For homes and businesses</b>				
Propane	12.68 gallon	5.75 gallon	138.63	62.88
Diesel and Home Heating Fuel (Distillate Fuel Oil)	22.45 gallon	10.19 gallon	163.45	74.14
Kerosene	21.78 gallon	9.88 gallon	161.35	73.19
Coal (All types)	3,876.61 short ton	1,758.40 short ton	211.87	96.10
Natural Gas	120.96 thousand cubic feet	54.87 thousand cubic feet	116.65	52.91

## Which electricity factor should be used?

- Public data source used in  
this example for electricity:  
eGrid 2020, U.S.  
Environmental Protection  
Agency



# Scenario & Baseline System Characteristics


## K-12 School in Atlanta

### Cooling

- Design load: 3,709 MBH
- Served by two 160 ton AC chillers
- 1.19 kW/ton FL, 0.744 kW/ton NPLV


### Heating

- Design load: 1,962 MBH
- Served by two 1,250 MBH natural gas boilers
- 90% AFUE





# Scenario & Baseline System Characteristics



# Baseline Emissions Calculation

$$\text{Annual emissions} = \frac{\text{Annual load}}{\text{Average efficiency}} \times \text{Average emissions factor}$$

## Heating:

$$\frac{294.16 \text{ MMBtu}}{0.9 [\text{efficiency}]} \times 116.65 \frac{\text{lb CO}_2\text{e}}{\text{MMBtu}} \left( 0.000454 \frac{\text{metric tons}}{\text{lb}} \right) = 17.29 \text{ metric tons CO}_2\text{e}$$

## Cooling:

$$\frac{3,539.12 \text{ MMBtu}}{13.42 [EER] / 3.412} \left( 293.07 \frac{\text{kWh}}{\text{MMBtu}} \right) \times 0.7198 \frac{\text{lb CO}_2\text{e}}{\text{kWh}} \left( 0.000454 \frac{\text{metric tons}}{\text{lb}} \right) = 86.11 \text{ metric tons CO}_2\text{e}$$

# Baseline Emissions

	Heating	Cooling
Annual load	294.16 MMBtu	3,539.12 MMBtu
Efficiency	90% (AFUE)	13.42 EER (0.894 kW/ton)
Input energy	326.84 MMBtu	263.76 MWh
Emissions factor	116.65 lb CO <sub>2</sub> e/MMBtu	719.77 lb CO <sub>2</sub> e/MWh
CO <sub>2</sub> e Emissions	17.29 metric tons	86.11 metric tons
Total Annual System CO <sub>2</sub> e Emissions 103.41 metric tons		

# Electrification Options

# Electric Boilers with Existing Chillers

## Equipment



Retain existing 160 tons air cooled chillers


- 1.19 kW/ton FL
- 0.744 kW/ton NPLV
- 42°F CHW



Replace natural gas boilers with electric boilers

- 300 kW electric boilers, 2050 MBH
- Electrical infrastructure consideration
- 110 °F HW

# Electric Boilers with Existing Chillers System




# Electric Boilers with Existing Chillers

## Emission Summary

	Heating	Cooling
Annual load	294.16 MMBtu	3,539.12 MMBtu
Efficiency	1 COP	13.42 EER (0.894 kW/ton)
Input energy	86.21 MWh	263.76 MWh
Emissions factor	719.77 lb CO <sub>2</sub> e/MWh	719.77 lb CO <sub>2</sub> e/MWh
CO <sub>2</sub> e Emissions	28.15 metric tons	86.11 metric tons
Total Annual System CO <sub>2</sub> e Emissions 114.26 metric tons		

# Emissions Comparison





# Air Source Heat Pumps with Electric Boiler Backup Equipment




Two (2) 180 nominal ton packaged ASHPs

- Sized for cooling
- 800 MBH oversized in heating
- 1.22 kW/ton cooling
- 2.45 COP heating



Optional backup boiler for redundancy

# Air Source Heat Pumps with Electric Boiler Backup System




# Air Source Heat Pumps with Electric Boiler Backup

## Emission Summary

	Heating	Cooling
Annual load	294.16 MMBtu	3,539.12 MMBtu
Efficiency	2.45 COP	13.64 EER (0.880 kW/ton)
Input energy	35.19 MWh	259.41 MWh
Emissions factor	719.77 lb CO <sub>2</sub> e/MWh	719.77 lb CO <sub>2</sub> e/MWh
CO <sub>2</sub> e Emissions	11.49 metric tons	84.69 metric tons
Total Annual System CO <sub>2</sub> e Emissions 128.91 metric tons		

# Emissions Comparison



# Ground Water Heat Pump


## Equipment



6 Pipe Modular heat pump with full heat recovery

- Average ground temp of 67°F
- Cooling - 310 tons, 0.62 kW/ton
- Heating - 4710 MBH, 5.28 COP
- Simultaneous – 267 tons cooling, 4060 MBH heating, 8.45 COP (0.944 kW/ton)

# Ground Water Heat Pump System




# Ground Water Heat Pump

## Emission Summary

	Non-Simultaneous		Simultaneous	
	Heating	Cooling	Heating	Cooling
Annual load	243.22 MMBtu	3,486.63 MMBtu	49.62 MMBtu	49.62 MMBtu
Efficiency	5.28 COP	10.35 EER 0.62 kW/ton	8.45 COP	12.71 EER 0.944 kW/ton
Input energy	13.50 MWh	180.14 MWh	1.72 MWh	3.90 MWh
Emissions factor	719.77 lb CO <sub>2</sub> e/MWh	719.77 lb CO <sub>2</sub> e/MWh	719.77 lb CO <sub>2</sub> e/MWh	719.77 lb CO <sub>2</sub> e/MWh
CO <sub>2</sub> e Emissions	4.41 metric tons	58.81 metric tons	0.56 metric tons	1.27 metric tons
Total Annual System CO <sub>2</sub> e Emissions				65.06 metric tons

# Emissions Comparison





# Heat Recovery with High Efficiency AC chiller and ASHP Equipment



## High Efficiency air-cooled chiller

- Sized for peak cooling
- 1.14 kW/ton FL
- 0.63 kW/ton NPLV



## Air-source heat pump


- Sized for peak heating
- 2.45 COP



## Heat recovery chiller

- Sized shy of peak simultaneous heating & cooling
- 40 tons
- 8.65 combined COP

# Heat Recovery with High Efficiency AC chiller and ASHP System




# Heat Recovery with High Efficiency AC chiller and ASHP

## Emission Summary



	Non-Simultaneous		Simultaneous	
	Heating only	Cooling only	Simultaneous: Heating	Simultaneous: Cooling
Annual load	243.22 MMBtu	3,486.63 MMBtu	49.62 MMBtu	49.62 MMBtu
Efficiency	2.45 COP	17.22 EER (0.697 kW/ton)	8.65 COP	12.71 EER 0.944 kW/ton
Input energy	29.09 MWh	202.43 MWh	1.68 MWh	3.90 MWh
Emissions factor	719.77 lb CO <sub>2</sub> e/MWh	719.77 lb CO <sub>2</sub> e/MWh	719.77 lb CO <sub>2</sub> e/MWh	719.77 lb CO <sub>2</sub> e/MWh
CO <sub>2</sub> e Emissions	9.50 metric tons	66.09 metric tons	0.55 metric tons	1.27 metric tons
Total Annual System CO <sub>2</sub> e Emissions				71.08 metric tons

# Emissions Comparison



# Heat Recovery with High Efficiency AC chiller and ASHP: Cascade for High Temp

Utilize heating loop as source to boost HW temp




# Conclusions


# Emissions Comparison – Projected Emissions

Georgia Power Company's 2022 Integrated Resource Plan (IRP) indicates that by 2030 it will rely significantly more on carbon-free energy and less on coal (State of Georgia Public Service Commission, 2022).

Based on the projected source mix in 2030, we can estimate the 2030 average emissions factor to be 593.26 lb CO<sub>2</sub>e / MWh



# Emissions Comparison – Projected 2030 Emissions







# Emissions Comparison – South Carolina

How would emissions change if this project was located in an area served by a less emissions intensive grid?

South Carolina has a 2020 annual emissions factor of 510.19 lb CO<sub>2</sub>e / MWh



# Emissions Comparison – South Carolina



# Conclusion: Key Takeaways

Emissions savings from electrification are highly dependent on a variety of factors:

- Location
  - Emissions factor for purchased electricity
  - Ambient conditions impacting efficiency of the system
- Energy sources
  - Is clean energy available either from the grid or a behind-the-meter source?
  - Design for sustainability: consider grid decarbonization over the lifetime of the system
- System conditions
  - Required supply temperatures
  - Will electrical upgrades be required?

# Bibliography

U.S. Energy Information Administration, 2022, Carbon Dioxide Emissions Coefficients. [eia.gov/environment/emissions/co2\\_vol\\_mass.php](http://eia.gov/environment/emissions/co2_vol_mass.php)

U.S. Environmental Protection Agency, 2022, eGrid Data Explorer. [epa.gov/eGrid](http://epa.gov/eGrid)

State of Georgia Public Service Commission, 2022, Document Filing #188519. [psc.ga.gov/search/facts-document/?documentId=188519](http://psc.ga.gov/search/facts-document/?documentId=188519)

Electric boiler image:

Laars Heating System Company, Commercial Electric Boiler. [laars.com/products/product/commercial-electric-boiler](http://laars.com/products/product/commercial-electric-boiler)

All images provided courtesy of Trane unless otherwise noted

# Questions

Dan Gentry

Dan.Gentry@trane.com

Emma Van Fossen

Emma.VanFossen@tranetechnologies.com